

## Analysis of Nigerian Electric Power System Frequency using FDR Measurements

<sup>1</sup>Musa Mohammed, &  
<sup>2</sup>Lawal M. Isah, M.  
<sup>1&2</sup>Department of Electrical  
Engineering Technology,  
Federal Polytechnic, Kaura-  
Namoda- Nigeria

### Abstract

This paper presents the result of prolong measurements and statistical data analysis of Nigerian power system frequency, obtained from Frequency Disturbance Recorder (FDR), the FDR installation experience, and also provides a comparative study between previous findings by other researchers and the present, in order to establish the current control status of the system. To assess the validity of the measurement, some part of the data were validated with data collected from Transmission Company of Nigeria (TCN). The result of 2016 indicates that the control action is worst as compared with the 2006, 2007, and 2011 results.

**Keywords:** *FDR, Frequency, Control action.*

*Corresponding Author*  
Musa Mohammed

## **Background to the Study**

Frequency is a very important parameter in Electric power system; it is a measure of balance between the active power generated and the active power consumed (Chudamani, 2009). At this balance, the frequency of the system is constant (Kothari, 2006), i.e. 50Hz in the case of Nigeria. Any mismatch between the generation and consumption (load plus losses) the frequency deviates from the nominal. Although there are other interferences that lead to the frequency deviation such as lightning, e.t.c., but at steady state, frequency is common all over the interconnected system (Luigi Vanfretti, Joe H. Chow, 2010). The Nigerian power system is characterized by insufficient generation, insufficient transmission lines, and incompatible governor controls (Sadiq, 2013), in such a situation, the system is exposed to risk of stress and the last resort is to introduce load shedding. Load shedding in Nigeria is done manually which is characterized by human error (Vanfretti Luigi, 2007). Load shedding, loss of load, loss of generation and transmission line trip causes frequency deviation.

One principal reason for Power system monitoring and control is to ensure that the frequency of the system did not deviate from the normal range (i.e.  $49.75 \leq f \leq 50.25$ ) (NERC, 2014). Any frequency outside this range subjects the system into risk of stress and if the frequency persists below 48.75 Hz, then the system will certainly collapse leading to serious black out, while impending damages in the case of frequency exceeding 51.25Hz, thus causing substantial economic loss and jeopardizing national security. It is therefore, essential to monitor and control the frequency in order to save the system from collapsing and prevent electrical/electronic equipments from damage.


In this paper, result of prolonged measurements of Nigerian power system frequency is discussed and a comparative analysis between different selected years and the present has been done in order to measure the current health status of the system. The remainder of this paper is organized as follows: section II described the implementation of Frequency Monitoring Network (FNET) structure and data capturing, Data validation is presented in section III, section IV provides the result of the analysis and comparative study between different years while section V draw conclusions of the work.

## **The FNET Implementation and Data Capturing**

### **The FNET Implementation**

The application of FDRs all over the interconnected power system for a wide area internet based centralized monitoring is known as FNET (Dong jin, 2013). Basically, the FNET comprises of two main components: the FDRs which serve as the sensor devices and the information management system (IMS). The FDRs perform local Global Positioning System (GPS) synchronized measurements of voltage phase angle, phase voltage magnitude and phase frequency. Thus these measurements are time stamped and reported at 0.1 seconds interval and then transmitted to the central server for further usage. The IMS handles the data collection, storage, communication, database operations, and web services (Dong jin, 2013). For the purpose of this research, a local frequency monitoring network (LFNET) was set up. The LFNET comprises of two main components; the FDR and a personal computer (PC) which serves as the information management unit. A small server program which normally comes with the FDR was installed in the PC to enable

connectivity for monitoring, data collection and storage. The basic LFNET frame work is shown in figure 1, the network was installed such that the GPS antenna is directly facing the sky in order to facilitate good reception. The FDR is directly connected to 230V socket. An external storage (Database) is incorporated to serve as a support to the PC as a huge amount of data is captured.



**Figure1: The Basic Framework of LFNET**

### Data Capturing

Following a successful implementation of LFNET, two month data were captured from the network during different days between January, February, and March, 2016. However, during the measurements a lot of outages and loss of GPS Signal were experienced. Figure 2 shows the screen shot of the data retrieving at a laboratory in the Department of Electrical and Computer Engineering Ahmadu Bello University, Zaria.

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
220	11316	105324	1	49.7708	49.7704	188.8792	1.7503	Success													
221	11316	105324	2	49.7704	49.7699	188.7365	1.6067	Success													
222	11316	105324	3	49.7696	49.7691	188.7047	1.4626	Success													
223	11316	105324	4	49.772	49.7715	188.7595	1.3188	Success													
224	11316	105324	5	49.7709	49.7704	188.724	1.1739	Success													
225	11316	105324	6	49.7691	49.7687	188.6176	1.0283	Success													
226	11316	105324	7	49.7683	49.7681	188.6534	0.882	Success													
227	11316	105324	8	49.7676	49.7676	188.6907	0.7349	Success													
228								GPS Signal Lost													
229	11316	105324	10	49.7636	49.764	188.6628	0.4393	Success													
230	11316	105325	1	49.7617	49.7619	188.7611	0.2931	Success													
231	11316	105325	2	49.7627	49.7635	188.7181	0.1444	Success													
232	11316	105325	3	49.7642	49.7651	188.7707	6.2781	Success													
233	11316	105325	4	49.763	49.764	188.8874	6.1275	Success													
234	11316	105325	5	49.7587	49.7597	188.8419	5.9774	Success													
235	11316	105325	6	49.7623	49.7632	188.8315	5.8266	Success													
236	11316	105325	7	49.7602	49.7608	188.8793	5.6733	Success													
237	11316	105325	8	49.7583	49.7588	188.8828	5.524	Success													
238	11316	105325	9	49.76	49.7602	188.9163	5.3722	Success													
239	11316	105325	10	49.7636	49.7635	188.962	5.2197	Success													
240	11316	105326	1	49.7543	49.7548	188.9744	5.0705	Success													
241	11316	105326	2	49.7586	49.7581	188.9506	4.9188	Success													
242	11316	105326	3	49.7599	49.7595	189.034	4.7668	Success													
243	11316	105326	4	49.757	49.7564	189.0512	4.6143	Success													
244	11316	105326	5	49.7556	49.755	189.0077	4.4615	Success													

**Figure 2: Screen showing data reception from LFNET**

### Data Validation

A two hour data was collected from TCN 132kV/33kV station in Zaria; corresponding to Monday 14<sup>th</sup> march, 2016 at 8pm to 10pm. the data were plotted together with the equivalent data of LFNET at one minute interval as shown in the figure 3. It can be seen from the plot that, a close agreement has been established between the two data, indicating and justifying the fact that frequency is a common measure all over the interconnected network.





Figure 3: Data validation plot.

### Analysis and Comparative Study of the Measurements


#### Data Plots Analysis

Some measures of dispersion as well as measure of central tendency were computed using SPSS Statistics software 2014 version. Also, in order to observe the stochastic city and probabilistic behavior of the frequency and to ease understanding of the system, a sampled plots, and probability distribution of the data were plotted using MATLAB R2013a version. Figure 4 shows a sample plot of the data. From the plot, it can be seen that the frequency is randomly changing moving out of the band that has been stipulated by Nigerian Electricity Regulatory Commission (NERC). This plot is an indication that sometimes the system operates under serious stress with below frequency threshold level, which simply means that the total Mega Watt (MW) load of the system is more than the total MW generated at that instant. The upper part of the graph shows over -frequency, meaning that the total generated MW is greater than the total MW load; in such a circumstance the loads that are rated to operate at 50 Hz suffer very much. Mostly over -frequency happens due to vigilant load-frequency control measures taken by the National Control Centre (NCC) in an attempt to avoid system collapse, consequently causing damage to the loads and the optimal utilization of the system is compromised.




**Figure 4: The Frequency Dynamics Plot**

The whole measurements were merged together in a way that the probabilistic behavior of the frequency can be assessed, which yield to a quasi-normal curve of figure 5. A healthy system is expected to produce a normal distribution curve with a narrow band between 49.75Hz and 50.25Hz ( $Hz/5.0=\Delta$ ) and a maximum probability distribution value at 50Hz. It is obvious from the graph that these benchmarks are clearly compromised.




**Figure 5: Probability Distribution of the Data**

Studies of events of different days reveal that the system frequency doesn't have a definite pattern. This can be seen from the figure 6 a.) And b.) Events of 11<sup>th</sup> and 12<sup>th</sup> January, 2016. The frequency is dynamically responding to the rising and falling trend of the load and generation.



a.) Frequency record of 11<sup>th</sup> January, 2016.



a.) Frequency Record of 12<sup>th</sup> January, 2016.

Figure 6: frequency Measurements Record of Different days

### A Statistical data analysis and comparison

The statistical indices of the prolonged measurement taken in 2016 have been computed, table 1 shows the summary of the result and comparison between some selected years and the present for the research to establish whether there is improvement in the control action or not.

Statistical Indices	Frequency,2011 (Hz)	Frequency,2007 (Hz)	Frequency,2006 (Hz)	Frequency2016 (Hz)
Min.	49.3	48.91	49.14	48.9948
Max.	50.59	51.28	51.26	51.6482
Mean	50.02	50.28	50.36	50.3429
Median	49.96	50.31	50.38	50.4337
Mode	49.81	49.56	49.78	49.6624
Std	0.1797	0.3954	0.269	0.5402
Range	1.288	2.374	2.118	2.6534

All the previous year's data were captured at Bauchi and was presented by (Kumo, 2012). To this extent, it can be observed that the result of 2016 measurements is worst in terms of control action as compared with that of 2006, 2007, and 2011 with regulation band  $Hzf6534.2=\Delta$ ,  $Hzf118.2=\Delta$ ,  $Hzf374.2=\Delta$  and  $Hzf2887.1=\Delta$  respectively. The mode of the frequency which is determine to be the main frequency at which the system mostly operates is outside normal hence the system mostly operates at stress. As well, the mean and standard deviation values of the data are not within the desirables.

### Conclusion

The analysis of Nigerian power system frequency has been presented in this paper. It has been established that the system mostly operates at serious pressures of stochastic under- and over-frequencies which are both undesirable. While comparing with previous year's assesment, it has been realised that the system frequency control is worse at present. In line with the current system situation, it is recommended that a better control infrastructure, such as frequency relay, used in load shedding be put in place, for proper control and optimal system utilization. Secondly, the power utility companies should endeavor to establish FNET system as it will provide accurate measurements, thus giving room for further research on the system dynamics and enhance proper monitoring and control. Finally, to overcome the problem of GPS signal lost encountered during the measurement a further research to developed prediction model is recommended, this will also serve as a means of system security to a situation that need urgent attention.

### References

- Chudamani, R. K. (2009). Real-Time estimation of Power System Frequency using Nonlinear Least Squares. *IEEE*.24, pp. 1-8. IEEE Transactions on power delivery.
- Dong, jin, X. M. (2013). Real-Time prediction of Power System Frequency in FNET:A state space approach. *IEEE Transaction on power delivery* .
- Kothari, I. A. (2006). *Power System Engineering*. New Delhi: Tata Mcgraw-hill Publishing Company.
- Kumo, M. S. (2012). *study and Analysis of Power System Frequency Variation*. Abubakar Tafawa Balewa University, Electrical Engineering . Bauchi: unpublished.
- Luigi, V. Joe, H. & Chow, U. A. (2010). Estimation of the Nigerian Power System Electromechanical Modes using FDR Measurements. 1-8.
- Nigerian Electricity Regulatory Commision. (2014). *Case Study in Service Quality Regulation in Nigeria*. the Engineering Standard and Safety Dvision, Abuja.
- Sadiq, A. A. (2013). Evaluation of Inter-area Available Transfer Capability of Nigeria 330KV Network. *Iintenational journal of science and technology*.
- Vanfretti, I, J. H. (2007). Building a Frequency Monitoring Network to Study Dynamics of Rapidly Growing Power Systems. *IEEE* (pp. 1-5). london: researchgate